

Energy Conservation for the Philippine Steel and Iron Industries: Case Studies

Loreto C. Carasi

**Philippine Council for Industry and Energy
Research and Development**

Department of Science and Technology

17 November 2006

Twin Tower Hotel, Thailand



OUTLINE

- ❑ **About DOST/PCIERD**
- ❑ **PCIERD EE & C Initiatives**
- ❑ **EE&C for the Philippine Steel and Iron Industry**
- ❑ **Conclusion**



DEPARTMENT OF SCIENCE AND TECHNOLOGY (DOST)

Premier science and technology body

Mandates:

- Central direction, leadership & coordination

- Policy, program & project formulation

- Councils, R&D Institutes, Service Institutes,
Regional Offices



DOST Sectoral Planning Councils

✉ **Philippine Council for Industry and Energy Research and Development (PCIERD)**

✉ **Philippine Council for Agriculture, Forestry and Natural Resources Research and Development (PCARRD)**

✉ **Philippine Council for Aquatic and Marine Research and Development (PCAMRD)**

✉ **Philippine Council for Advanced Science and Technology Research and Development (PCASTRD)**

✉ **Philippine Council for Health Research and Development (PCHRD)**

- 
- R&D
 - INSTITUTION BUILDING
 - MANPOWER DEV'T AND SCHOLARSHIP
 - SEMINARS AND CONFERENCES
 - TECHNOLOGY TRANSFER
 - POLICY DIRECTIONS



PCIERD Mandates

- ❑ Industry & energy policies, strategies, plans and programs
- ❑ Fund programming & allocation
- ❑ Project & program monitoring
- ❑ External fund generation



Services Offered by PCIERD

- ☐ Provides Grants-in-Aid (GIA)
- ☐ Grants applied S&T scholarships
- ☐ Disseminates & promotes S&T information
- ☐ Supports scientific & technological services



SECTORAL COVERAGE

- ❑ FOOD & FEED
- ❑ PROCESS /CHEMICAL
- ❑ TEXTILE AND GARMENTS
- ❑ MINING & MINERALS
- ❑ METALS & ENGINEERING
- ❑ ENERGY
- ❑ TRANSPORTATION
- ❑ CONSTRUCTION
- ❑ ENVIRONMEN
- ❑ DISASTER AND MANAGEMENT



PCIERD EE & C Initiatives

❑ Capacity Building

- ❑ Establish Core of Experts in the Region
- ❑ Factory Energy Audit on SMEs
- ❑ GAP Funded
- ❑ PCIERD Funded

❑ Infrastructure Support

- ❑ Provision of equipment

❑ Policy Support

- ❑ Report to DOE the DOST's Energy Savings
- ❑ Establishment of Vehicle Research and Testing Facility
- ❑ Promotion of Biofuels



EE & C for the Philippine Steel and Iron Industry

- **Objectives of the program:**
 - To provide technological exchange of information and expertise
 - To conduct human resources development
 - To conduct energy audit and technical assessment on the selected industries
 - To establish network and linkages among the local and Japanese industries



Company A

● **Products**

- Plain and deformed steel bars and rods for concrete reinforcement

● **Production capacity**

- 250,000MT per year

● **Total Energy consumption per year**

- Electricity
 - 25 Mw-hr
- Fuels
 - 9,500 Kilioliters

● **Number of employees**


- 147

● **Location**

- Metro Manila



Furnace



Findings:

- Preheated Air : Defective instrument to grasp the preheated air temperature
- Recuperator: Defective recuperator tubes
- Waste Gas Loss: Temperature of outlet is 798 °C
% Oxygen in flue gas is 3.8%
- Heat Loss from Charging Door: Temp. of gas from charging door is 691 °C
Open space is measured at 0.92 m²
- Induced Air from Discharging Door: Amount of air is 4,900 m³ per hr
- Discharging Operation: No problem
- Heat Loss from Surface: Temperature of furnace shell external surfaces
(roof and side walls) is 90-100°C
- Burner: Straight type burners is used



Cooling System (Pumps)

- ❑ Skid Furnace
 - ❑ Operates well
- ❑ Mill
 - ❑ Motor loading is low
- ❑ Quench
 - ❑ Motor loading is low



Compressors

- ❑ Loading and Unloading time : Ok
- ❑ Load requirements vs. Delivery capacity: Ok
- ❑ Discharge Pressure vs. Required Pressure at the User Side : Decrease the discharge pressure gradually
- ❑ Leakage Along Supply Line
- ❑ Draining of Moisture



Implemented Measures

Furnace:

- Instrument wirings on the control panel were modified to get readings of pre-heated air
- Repair of recuperator to eliminate air leakage
- Installation of “heat curtain” at the charging door of furnace to minimized heat loss (Later replaced with sliding-plate type)
- Reduction of induced air from discharging door
- Improvement of burner combustion efficiency
- Minimizing heat loss from furnace
- Improvement of furnace data monitoring



Implemented Measures

Pumps/Blowers:

- Improvement of combustion blower motor loading
 - The 100 HP motor for combustion blower was replaced with a 75 HP motor. The motor loading was increased from 70% to 95%.
- Repair of Rolling Mill Circulating Pump
 - The impeller was replaced and the seal ring was repaired. Motor loading was increased from 70% to 95%.

Air Compressors:

- Minimized air leakage in the system
 - Conduct leak test for the air supply
 - Correction of air leakages in the system is a continuing program


Mill bay Lighting

- Used/installed skylights at strategic locations inside the mill to enhance illumination.




Fuel and Power Consumption Trends

Power



Electricity



	2001	2002	2003	2004	2005
Fuel, Lit/ton	45.88	45.77	42.9	39.26	36.51
Power, Kw-hr/ton	97.22	98.28	106.58	104.04	98.87



Amount of Energy (2004)

Particular	Energy Savings		
	Lit/ton	%	Savings (Peso)
Reduction in Fuel	3.64	8.48	4.167 M
Reduction in Power	Kw-hr/ton	%	Savings (Peso)
	2.54	2.38	1.418 M
TOTAL ENERGY SAVINGS			5.585 M



Amount of Energy (2005)

Particular	Energy Savings		
	Lit/ton	%	Savings (Peso)
Reduction in Fuel	2.75	7.0	3.4M
Reduction in Power	Kw-hr/ton	%	Savings (Peso)
	5.17	4.97	2.8 M
TOTAL ENERGY SAVINGS			6.2M



Plans

- Lengthen the heating zone of the furnace to reduce flue gas temperature
- Additional insulation on the furnace shell outside surfaces
- Use of inverter control for the TTL process pumps
- Replacement of straight-type burners to swirl type burners
- Close Monitoring of plant power factor to ensure PF is always at its optimum
- Recycling of used oil and grease
- Provision of pneumatic lubricator
- Continue the checking/repair of air leakages in the plant



Company B

- **Products**

- Deformed bars

- **Production Capacity**

- 121,337.22 MT per year

- **Annual Energy Consumption (average)**

- Electricity = 13.4 MWH
- Fuels = 4,114 kiloliters

- **Number of Employees**


- 185

- **Location**

- Metro Manila



Furnace



Findings:

Preheated Air Temp : Low @ 224°C

Recuperator: Check leakage

Waste Gas Loss: Waste gas temperature at recuperator inlet is quite low at 665°C

Heat Loss from Charging Door: Temp. of gas from charging door is 680 °C
Open space is measured at 0.92 m²

Induced Air from Discharging Door: Amount of air is 1,100 m³ per hr

Discharging Operation: 2-3 billets are discharged together, and the 2nd and 3rd billets cannot be rolled coz its temp. has lowered and thus require further heating

Heat Loss from Surface: Temperature of furnace shell external surfaces
(Ceiling: 100-130, Side: 85-95°C)

Burner: Straight type burners is used

Furnace Scale Generation: The ave. concentration for waste gas oxygen concentration is 1.7%




Implemented Measures

- Replacement of existing recuperator
- Installation of insulation curtain at the inlet door of the furnace
- Reduce opening time of billet discharge door
- Reduction of waste gas oxygen concentration from 1.7% to 1.3%
- Raising the furnace pressure setting
- Optimization of Billet Reheating Furnace
- Application of cladding insulation on the oil pipe lines
- Increase setting of oil heaters at the main line (soaking and heating zone) from 90°C to 110°C
- Set-up energy conservation group




Fuel and Power Consumption Trends

Power



Electricity



	2003	2004	2005
Fuel, Lit/ton	36.39	33.45	30
Power, Kw-hr/ton	109.19	108.56	108



Amount of Energy (2004)

Particular	Energy Savings		
	Lit/ton	%	Savings (Peso)
Reduction in Fuel	2.94	8.08	4.206M
Reduction in Power	Kw-hr/ton	%	Savings (Peso)
	0.63	0.51	0.444M
TOTAL ENERGY SAVINGS			4.65 M



Amount of Energy (2005)

Particular	Energy Savings		
	Lit/ton	%	Savings (Peso)
Reduction in Fuel	3.45	10.31	5.074M
Reduction in Power	Kw-hr/ton	%	Savings (Peso)
	0.56	0.52	0.377 M
TOTAL ENERGY SAVINGS			5.451M



Plans

- BRF heat conservation (charging and discharging side)
- BRF waste gas temperature monitor and control
- Use of stand alone electric furnace in preheating pre-determined steel
- Demand KW monitor and control
- Make-up water volume monitor and control
- Compressed air leakage monitor and control



Company C

- **Products**
 - Galvanized and Pre-painted Sheets/Coils
- **Production capacity per year (average)**
 - **Continuous Galvanizing Line (CGL)**
 - 34,703 tons
 - **Color Coating Line (CCL)**
 - 27,588 tons
- **Total Energy Consumption (average)**
 - **Electricity**
 - **CGL**
 - 1,058 MWh per year
 - **CCL**
 - 845 MWh per year



Total Energy Consumption (average)

- **Fuel consumption per year**
 - **CGL**
 - Fuel Oil: 577,728 liters
 - LPG: 256,513 kgs.
 - **CCL**
 - LPG: 492,170 kgs.

● **No. of employees**

- 170

● **Location**

- Laguna



Power and Electricity Consumption Trend

Continuous Galvanizing Line (CGL)

	2003	2004
Energy Consumption		
BFO/SFO, Liters	625,497	529,959
LPG, Kgs	290,349	222,678
Power, Kw-hr	1,196,234	920,634
Rate of Consumption		
BFO/SFO, Lit/ton	17.172	16.069
LPG, Kg/ton	7.971	6.752
Power, Kw-hr/ton	32.841	27.914



Power and Electricity Consumption Trend

Color Coating Line (CCL)

	2003	2004
Energy Consumption		
LPG, Kgs	576,477	407,863
Power, Kw-hr	954,965	734,896
Rate of Consumption		
LPG, Kg/ton	19.106	16.313
Power, Kw-hr/ton	31.650	29.393



Particulars	Energy Savings		
Reduction in Fuel	Kgs. per ton of product	% Savings	Savings (Peso)
LPG <ul style="list-style-type: none"> ● CGL ● CCL 	1.219 2.793	15.3 14.6	1.327 M 2.304 M
	Lits. per ton of product		
Bunker Oil <ul style="list-style-type: none"> ● CGL 	1.103	6	0.654 M
	KW-hr/ton		
Reduction in Power <ul style="list-style-type: none"> ● CGL ● CCL 	4.927 2.257	15 7.1	1.075 M 0.305 M
TOTAL			5.665 M



Implemented Measures

- **System Improvement**
 - Improved treading time from 5-6 minutes to 3 minutes
 - Installation of cartridge type coaters to reduce downtime in changing colors and replacing paint coater rolls
 - Installation of 12.5 MT overhead crane to handle bigger coil materials
 - Installation of horizontal direct fired LPG preheater
 - Change technology from zinc lead-lead-zinc hot dip galvanizing to a modified John Lysaght process
 - Installation of direct fired LPG coil heater
- **Conduct study on peak kW**
 - Reduced demand at CGL furnace
 - Reduced demand at CCL oven
- **Improvement of power factor from 81% to 94%**
- **Improvement of light distribution at CCL**



Plans

- Decommission boiler using BFO
- Shift of fuel materials from BFO to SFO
- Improve burner firing at LPG preheater
- Decommission air dryers, exhaust gas from LPG direct fired alkali heaters used as air dryers
- Decommission smoothener rolls drive of 7.5kW
- Waste heat recovery at LPG heaters and dryers
- Conduct efficiency tests in ovens and furnaces for temperature profiling



Common measures implemented

- Minimizing heat loss from furnace
- Improvement of burner efficiency
- Improvement of pump motor loading
- Minimized compressed air leakage

Common plans

- Heat conservation on the reheating furnace
- Waste gas temperature monitor and control
- Demand kW monitor and control
- Make-up water volume monitor and control
- Compressed air leakage monitor and control



Conclusion

- **The participating factories shows positive response.**
 - Recommended measures or areas of improvement suggested by the experts have been implemented and it was reported that there was a great improvement in plant efficiency and significant savings was realized.
 - Local skills were enhanced and they can now do energy audit by their own.
- **The significance of Energy Conservation and Management has been recognized, which is evident to their new initiatives.**
 - Setting-up of company's energy conservation targets
 - Creation of energy managers and auditors
 - Energy conservation are discussed during management meetings



Thank You

PCIERD Website

<http://www.pcierd.dost.gov.ph>

