

WELCOME

ENERGY AUDIT TEAM & AUDIENCE



BANGKOK STEEL INDUSTRY PUBLIC CO., LTD.

BSI LOCATION

27 M.10 Poochaosamingprai Rd.

Phrapradang , Samutprakarn

10130, Thailand

Tel : 02-754-4617

Fax : 02-754-4666

BANGKOK STEEL INDUSTRY PUBLIC CO.,LTD.

- (1964) Company **establishment** re-rolling steel mill (Capital 70 M Baht)
- (1973) **Started** manufacture **steel bar 25 MT (E.A.F system)**
- (1978) Major shareholder by **Metro company Limited**
- (1983) **Join venture** with Nissho Iwai Corp. and Nomura Trading Co., Ltd. to Manufacture galvanized iron steel sheet (C.G.L #1)
- (1991) Registered in the **Stock Exchange of Thailand**
- (1992) **Constructed C.G.L #2 and C.C.L** (Prepainted galvanized steel)
- (1993) Installed **additional 25 MT E.A.F** and new **Rolling mill factory R.M #1**
- (1994) Transformed into **public company** limited by shareholders Meeting Approval (Capital 40 M Baht)
- (1996) Constructed another rolling mill **R.M #2** and new factory in Nakornrachasima
- (1997) Constructed another new Galvanized steel **C.G.L #3 in Nakornrachasima**

BSI: MAJOR PRODUCTS

CONCREAT REINFORCED STEEL

:

DEFORM BAR

&

ROUND BAR

GRADE: SR 24, SD 30, SD 40, SD 50

SIZE: RB 6, 9, 12, 15, 19, 25, 28

SIZE: DB 6, 12, 16, 20, 25, 28, 32, 40

BS I

**: Melt Shop
(EAF 25 T. x 2)**

**: Rolling mill
(Hot Roll 50 T/h , 70T/h)**

Electric Arc Furnace (EAF)



Scrap Loading



Bucket, Weighing



Charging to EAF



EAF Melting
1,550 °



Sample test




Chemical Adjust



Slag taping



Taping to L/D



Continues Casting Machine (CCM)



L/D Send to CCM



Casting



Cooling



Billet \varnothing 130



Cooling Bed



Ware house

ROLLING MILL (RM)



**Push Billet to
RHF 1,150**



**Discharge to
Roll Stand**



**Rolling (Roughing
Intermediate,
Finishing)**



**Forming and
Marking
(Finishing Stand)**



Ware house



Tying & Tacking



Cutting to Order



Cooling

Energy

Top Management Policy:

**Encourage to energy conservation
and follow the ministry of energy's
policy**

BSI

Energy

Committee



บริษัท มาตรฐานผลิตภัณฑ์อุตสาหกรรม จำกัด (มหาชน)

27 หมู่ 10 ถนนสุวินัยวงศ์ ตำบลคลองหลวง อำเภอคลองหลวง จังหวัดปทุมธานี โทร. 02-562-1111

18 ตุลาคม 2561

เรียน คุณวิฑูรย์ สีนันทนา

ตามที่คณะกรรมการพลังงาน ได้ขอเชิญคุณวิฑูรย์ สีนันทนา มาเป็นสมาชิกคณะกรรมาธิการพลังงานของประเทศไทย โดยคุณวิฑูรย์ สีนันทนา ได้ตอบรับที่จะเข้าร่วมเป็นสมาชิกคณะกรรมาธิการพลังงานของประเทศไทย เมื่อวันที่ 18 ตุลาคม 2561

เพื่อให้คณะกรรมการพลังงานสามารถดำเนินการตามหน้าที่และอำนาจได้ คณะกรรมาธิการพลังงานได้แต่งตั้งคุณวิฑูรย์ สีนันทนา เป็นสมาชิกคณะกรรมาธิการพลังงาน โดยคุณวิฑูรย์ สีนันทนา จะทำหน้าที่ตามที่ได้รับมอบหมายต่อไป


1. นายสมชาย ธีระกุล	สมาชิกคณะกรรมาธิการ	ประธานคณะกรรมาธิการ
2. นายสมชาย ธีระกุล	Executive Engineer	ผู้ช่วยประธานคณะกรรมาธิการ ฝ่ายเทคนิคและวิศวกรรม
3. นายวิฑูรย์ สีนันทนา	Senior Engineer	ผู้ช่วยประธานคณะกรรมาธิการ ฝ่ายเทคนิคและวิศวกรรม
4. นายสมชาย ธีระกุล	Senior Engineer	ผู้ช่วยประธานคณะกรรมาธิการฝ่ายเทคนิค
5. นายสมชาย ธีระกุล	Senior Engineer	คณะกรรมการฝ่ายเทคนิคและวิศวกรรม
6. นายวิฑูรย์ สีนันทนา	วิศวกรโยธา	คณะกรรมการฝ่ายเทคนิคและวิศวกรรม
7. นายวิฑูรย์ สีนันทนา	วิศวกรโยธา	คณะกรรมการฝ่ายเทคนิคและวิศวกรรม
8. น.ส. สีนันทนา สีนันทนา	ผู้ช่วยเลขานุการ	ผู้ประสานงานคณะกรรมาธิการพลังงาน BSI

จึงเรียนมาเพื่อทราบและขอเชิญ

วิฑูรย์ สีนันทนา
ผู้ประสานงานคณะกรรมาธิการ


สมชาย ธีระกุล
ประธานคณะกรรมาธิการ

BSI Energy




■ Electric Energy ■ Heat Energy

BSI Energy (Electric Energy)





- Electric Arc furnace
- Motor (> 20kW)
- Cooling system
- Air compressor
- Air conditioning
- Lighting system
- Other

BSI Energy (Heat Energy)



Heavy Oil



Implementation

Example for

Energy

Conservation

1. Implementation of lighting system

RM. Roof

Original: Metal sheet

Modified: Transparent sheet in some section

Saving: 177,870kWh/y

Saving: 425,000Baht/y

Budget: 423,330Baht

2. Implementation of cooling tower

RM. Cooling tower

Original: Aluminum fan (10.6kgs/paddle

Motor load: 23.7A)

Modified: Glass fiber (6.1kgs/paddle

Motor load 16.3A)

Saving: $7.4A = 1628W \times 3sets$

Saving: 80,077Baht/y

Budget: $35,000 \times 3sets = 105,000Baht$

3. Implementation dryer of QTB

RM. QTB

**Original: Used power $24\text{h} \times 33\text{kW} = 792\text{kWh}$
= 546,480Baht**

**Modified: Used power $(1\text{min} \times 900\text{bar/day} \times 33\text{kW}) / 60\text{min} = 495\text{kWh}$
= 341,550Baht**

**Saving: Compress air pipe 10mm. diameter at 7bar
using the power 33kW Speed a bar passing
the QTB consumes is 1min**

Saving: 204,930 Baht/y

Budget: No budget

4. Implementation gate of RHF

Original: The gate size at open position is $350 \times 700\text{mm}$.

Modified: The gate size at open position is $180 \times 700\text{mm}$.

Saving: Save energy from heat lost: $43,628.87\text{kJ/h}$

Saving: $7,632\text{L} \times 13\text{Baht/L} = 99,216\text{Baht/y}$

Budget: No budget

5. Implementation of air nozzle for tying machine

Original: Air nozzle is open all the time

Modified: Control by timer & solenoid valve

**Saving: Compress air pipe 5mm. diameter at 7bar
using the power 8.3kW**

Saving: 137,408.26Baht/y

Budget: 20,000Baht

6. Implementation of power unit for chain transfer

Original: Chain transfer use a big hydraulic pump running all the time

Modified: Small electric motor running only the bar passing

$$\begin{aligned} & \text{Electric motor } 5.5\text{kW} \times 24\text{h} \times 60\% \text{ running} \times 300\text{day} \times 2.3\text{Baht} \\ & = 54,648\text{Baht} \end{aligned}$$

Saving: 442,152Baht/y

Budget: 50,000Baht

7. Replaced pinch roll and Roller conveyer by pipe conveyer

Original: Pinch roll & Roller conveyor 0.75kW × 10sets

Modified: Pipe conveyor (Non use Power)

Saving: 40.5kWh (291,600kWh/y)

Saving: 670,680Baht/y

Budget: 100,000Baht

8. Implementation of roller conveyer

Original: Motor 0.75kW 40sets

Modified: Motor 0.75kW 40sets

Saving: 86,940Baht/y

Budget: No budget

**Implementation on the blower
and bag filler, bag house of dust
collector (MS)**

**Replaced vane type air compressor
by turbo air compressor**

Energy Audit In

PROMEEC Team Member



**Department of Alternative Energy Development
and Efficiency (DEDE)**

Mr. Sarat Prakobchat

Mr. Somchat Tanglikhasit

Mr. Vachira Jindaphet

Mr. Chawalit Boonsang


Mr. Amornsak Rangsakorn

Mr. Pornchai Thernnoo

Mr. Cheerawat Nuannuam

Energy Audit In

PROMEEC Team Member



**BANGKOK STEEL INDUSTRY
PUBLIC CO., LTD.**

Mr. Somchai Khamphoo

Mr. Taned Dejamornton

Mr. Pongsthorn Rienthong

Mr. Sumrong Boonchalee

Mr. Pornthep Suwanmanee

Mr. Taweechai Sornchui

Mr. Jakaphol Nounkhain

Mr. Anan Thaicharoen

ECCJ

Mr. Hideyuki Tanaka

Mr. Kokichi Takeda

ACE

Ms. Evangeline L. Moises

Mr. Ivan Ismed

Working Step

1. Brief Company History

- **Name & Foundation of Company**
- **Type of products, Ratio**
- **Capital**
- **Annual Sales**
- **Annual Energy Cost**
- **Employees, Technician, Engineer, Manager**
- **Energy Conservation Committee**

2. Data Collecting

- **Equipment**
- **Specification**
- **History**
- **Operation plan**
- **Working time**
- **Drawing & Documents**

3. Annual Utility Consumption

4 - 5 years

Electricity		Heat Energy		Compressed Air		Water	
All, Each machine							
#	TOU , TOD	#	Fuel oil	#	consumption	#	City water
#	Partial time	#	Diesel oil	#	pressure	#	Deep well water
#	Peak time	#	Kerosene			#	Re use water
		#	LPG				
		#	Oxygen				
		#	Coke , etc.				

4. Annual Cost 4 – 5 years

- **Fuel Cost**
- **Power Cost**

5. Site Inspection

Plan for Inspection

- **Specified item requires especially**
- **Energy conservation measures implemented so far**
- **High consumption machines**

6. Discussion for EC measures

- **In put Energy: Out put Energy**
- **Data Specification: Inspection**
- **Expected Energy saving: Investment**

Energy Audit Results

Data analysis

- **Energy consumption**
- **Unit consumption**
- **Specific Energy Efficiency Index**

1. Reheating Furnace: Recommend to check, adjust, repair

- **By Pass Valve of Air Recuperator**
- **Thermocouple of Air Recuperator**
- **Pressure Transducer (Std. + 0.3 to + 0.5 mm H₂O)**
- **Decrease Area of door**
- **Insulation (Std. wall < 100 ·c , top < 110c)**
- **Oil saving 1.6%**

- **Air ratio**
 - **m: 1.235 (O₂ content, 4 % in flue gas)**
Std. m < 1.15 (O₂ content, 2.74 % in flue gas), Oil saving ~ 1.3 %
 - **Scale loss < 2.4 %**
 - **Installation of gas analyzer**
 - **Reduction of furnace opening (Charger)**
 - **Reduction of door size and opening time**

2. Compressed Air

- Air Leakage
- Capacity of pressure tank
- Piping Loss

3. Water pump for EAF

- Installation small pump
- Installation of Inverter
- Impeller Cutting

4. Ladle heating

- Heat recovery of waste heat of exhaust gas

5. CCM

- Ladle cover during casting
(Low Tap temperature Saving ~ 70L/heat)
- Heat insulation of molten steel flow
Ladle - Tundish - Mold

6. Billet yard

- Heat insulation cover for hot Billet
- Warm charge to RHF - Hot charge
(30 - 130 °c Saving 360kL/y)

All the Time

You Ready To

Start

Energy

Conservation

BSI Energy Conservation

Presentation by

Mr. Somchai Khamphoo

Tel: 02 754 4617, 081 645 9505

Website: <http://www.bangkoksteel.co.th>

E-mail: somchai.khamphoo@bangkoksteel.co.th